



NOTE:
DETAILS APPLICABLE TO
ALL UNITS

AIR HANDLING UNIT SCHEDULE																
SELECTION BASED ON:		FAN DATA				FAN MOTOR		CAPACITIES (MBH)			STRIP HEATER			ELECTRICAL DATA		
DESIGNATION	MODEL NO.	HEATER	CFM SUPPLY	CFM O.A.	EXT. S.P. IN. W.G.	H.P.	AMPS	COOLING TOTAL	HEATING TOTAL	K.W.	STEPS	VOLTS PHASE	MCA	MDCP	WT. (LBS)	
AHU-A	FF10NAD1800S	SKW	600	---	.3	1/12	0.7	17.2	12.0	17.2	5.0	1	240/1P	55.9	30	75

CONDENSING UNIT SCHEDULE													
SELECTION BASED ON:		COMPRESSOR DATA		FAN MOTOR		EFFICIENCY		ELECTRICAL DATA					
DESIGNATION	MODEL NUMBER	RLA	LRA	H.P.	AMPS	SEER	COP	VOLTS PHASE	AMPS	MDCP	WT. (LBS)		
CU-1	38CKC018	9.0	48.0	1/8	0.8	10.05	N/A	240/1P	12.8	20	113		

AC-1
PLENUM 15X14 3/4"
SUCTION LINE 5/8" COPPER WITH 1/2" CLOSED CELL INSULATION
LIQUID LINE 3/8" COPPER
CONDENSATE 3/4" PVC SCH. 40

NOTES:
1. POWER AND CONTROL WIRING BY E.C.
2. EXHAUST FANS SUPPLIED AND INSTALLED BY FHAC
3. COND. DRAIN LINES BY PLUMBER, FINAL CONNECTIONS BY FHAC

RECEIVED
MAY 2 2001

UNIT-'A'/'AR'

FHAC #205811-1

REVISIONS
DATE: 3-14-01
SCALE: AS NOTED
DRWG. BY: JRH
CHECKED: CW
THE GRAND AT PALM BEACH GARDENS-UNIT A
KOLTER BUILDERS
FLORIDA HEATING & AIR CONDITIONING, INC.
1700 BANKS ROAD, MARGATE, FL 33065 (305) 973-0900
SHEET NO.
AC-1